

Specification for Underground Service Meter Pedestal



Cooperative furnishes pole, loop with wire and conduit meter pedestal.

Member Electrical:

Furnishes and installs the 200 amp breaker, UG service wire, and conduit below the meter.

Breaker required: Westinghouse CA2200W or Cuttler Hamer CA2200

Known sources for these breakers
 Elliot Electric, Killeen, TX (254) 554-958
 Rockdale Building Center (512) 446-5884

NOTES:
 All wiring must conform to National Electric Code, National Electrical Safety Code, and Municipal Code as required.
 Municipal jurisdiction will require city inspection of loop before connection.
 Notify Bartlett Electric Cooperative when breaker is installed.
 Bartlett Electric Cooperative pole must remain free of structures and private attachments other than meter loop riser assembly.

Bartlett Electric Cooperative, Inc.
 27492 Hwy 95
 P O Box 200
 Bartlett, TX 76511

Revised 1-09-09 sks
 Approved: KS

254-527-3551
 (Fax) 254-527-3221